



EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası KOCAELİ/TÜRKİYE
www.effectis.com

TEST SERTİFİKASI

Sertifika No: EEA-1800-0031-REV

Aşağıda tanımlanan ürünün ilgili yangına dayanım testi TS EN 1364-1:2015 standardına uygun olarak **Efectis Era Avrasya Test Laboratuvarı**'nda 30.03.2018 tarihinde gerçekleştirilmiştir:

POLİİZOSİYANURAT (PIR) YALITIMLI SANDVIÇ PANEL CEPHE SİSTEMİ "ALUFORM PLATINUM"

YANGINA DAYANIM SINIFI
E 120, EI 45

Piyasaya Süren Firma
ALUFORM PEKİNTAŞ ALÜMİNYUM SAN. VE TİC. A.Ş
Büyükdere cd. No: 32 Pekintaş İş merkezi Mecidiyeköy - ŞİŞLİ/İSTANBUL/ TÜRKİYE

Üretici Firma
ALUFORM PEKİNTAŞ ALÜMİNYUM SAN. VE TİC. A.Ş
D-100 Karayolu İstilli Köyü mevkii 81000 DÜZCE - TÜRKİYE

Bu test sertifikası test sonuçlarının bir beyanıdır ve ürünün tip onayını veya belgelendirmesi temsil etmez. Ürün özellikleri ve uygulama alanı ile ilgili tüm detayları **EEA - 18- 018-rev** No.lu raporda tanımlanmıştır.

Bu sertifika, ilgili test ve sınıflandırma standartlarında ve numunenin teknik özelliklerinde herhangi bir değişiklik yapılmadıkça başlangıç olarak 10 Eylül 2021 tarihine kadar geçerlidir.

Ali BAYRAKTAR
Laboratory Manager
10.09.2020





EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası KOCAELİ/TÜRKİYE
www.effectis.com

TEST CERTIFICATE

Certificate Nr: EEA-1800-0031-REV

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratories** on 30.03.2018 in accordance with EN 1364-1:2015 standard for the product as described below:

POLYISOCYANURATE (PIR) INSULATED SANDWICH PANEL FACADE SYSTEM "ALUFORM PLATINUM"

FIRE RESISTANCE CLASSIFICATION

E 120, EI 45

Placed on the market by
ALUFORM PEKİNTAŞ ALÜMİNYUM SAN. VE TİC. A.Ş
Büyükdere cd. No: 32 Pekintaş İş merkezi Mecidiyeköy - ŞİŞLİ/İSTANBUL/ TURKEY

And Produced In the Factory
ALUFORM PEKİNTAŞ ALÜMİNYUM SAN. VE TİC. A.Ş
D-100 Karayolu İstilli Köyü mevkii 81000 DÜZCE - TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **EEA – 18– 018-rev.**

This certificate is initially valid until 10th September 2021 providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.

Ali BAYRAKTAR
Laboratory Manager
10.09.2020

